

*Handwritten signature and date: 22-4-24*

Government of Bihar

District Level Water Testing Laboratory, Khagaria

PUBLIC HEALTH ENGINEERING DEPARTMENT

PHYSICO-CHEMICAL & BACTERIOLOGICAL TEST REPORT

Order No - 698, Date - 22-04-2024

Division - P.H Division khagaria	Sample Collected By- Sanitary Inspector SH Khagaria	DATE OF Sampling - 20.04.2024
Location Name - Khagaria	Sample Submitted By- Sanitary Inspector SH Khagaria	DATE OF Testing - 22.04.2024
Testing Method -Chemical Method	Source of Sample- RO Water (Ground Water)	DATE OF Reporting- 22.04.2024

  

Location Details	Chemical Parameter mg/l								
	TDS	PH	Iron	TH	Chloride	Fluoride	Alkalinity	Arsenic	
St.Xaviers High School (ACC-Mission) Tikarampur, Mathurapur Khagaria 851204	86.00	7.10	0.32	54.00	12.00	0.21	26.00	BDL	
Desirable Limit*	500	6.5	1.0	200	250	1.0	200	0.01	
Permissible Limit in absence of Alternate Source**	2000	8.5	NR	600	1000	NR	600	NR	

*Handwritten signature*  
Chemist  
P.H Division

*Handwritten signature*  
22-4-2024  
Executive Engineer  
P.H. Division Khagaria

*Handwritten signature*  
**PRINCIPAL**  
ST. XAVIER'S HIGH SCHOOL (ACC-MISSION)  
TIKARAMPUR, MATHURAPUR  
KHAGARIA-851204 (BIHAR)

*Handwritten signature*  
**MANAGER**  
ST. XAVIER'S HIGH SCHOOL (ACC-MISSION)  
TIKARAMPUR, MATHURAPUR  
KHAGARIA-851204 (BIHAR)